

1. **Unique Product Identification Code:** Smoke PROtec - SN: 752005000006
2. **Intended Use:** Static Smoke Barrier SSB
3. **Manufacturer:** SIMON PROtec Systems GmbH
 Manufacturer address: Medienstraße 8
 D-94036 Passau
 Germany
4. **System assessment:** System 1
5. **Notified body:** MPA Braunschweig
Notified Body Number: 0761
EC Certificate Number: 0761-CPR-0206
Harmonized Standard: EN 12101-1:2005

6. **Declaration of Performance:**

Essential Characters:	Declared Performance:
Clear opening	100000 x 500 mm
Fire resistance class (600 °C)	D 120
Maximum permeability of the smoke barrier	0,3 m ³ /h

Openings, gaps and perimeter spaces around the perimeter:			
Gap	Housing (a - f)		0 mm
Gap	Housing left (g)		0 mm
Gap	Housing right (g)		0 mm
Gap	Connection (h)		0 mm
Perimeter Space	Housing	100000 x 0 =	0.00 mm ²
Perimeter Space	Housing left	500 x 0 =	0.00 mm ²
Perimeter Space	Housing right	500 x 0 =	0.00 mm ²
Perimeter Space	Connection	500 x 0 =	0.00 mm ²
Perimeter Space	Total		0.00 mm ²

The performance of the product identified in point 1 is in conformity with the declared performances in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

